

TECHNICAL NOTE

**VICTAULIC COMPANY
TECHNICAL SERVICE BULLETIN**

UNITED Fire Systems proudly uses Victaulic FireLock NXT™ Preaction Valves in its PREACTION-PAC Sprinkler Valve Assemblies.

In keeping with its commitment to quality, Victaulic has issued a Technical Service Bulletin regarding inspection of these valves. UNITED Fire Systems is passing this important information on to its clients.

Please refer to Page 2 of this Technical Note for this Victaulic Technical Service Bulletin.

Please contact UNITED Fire Systems with any questions regarding this bulletin. Thank you.

Victaulic FireLock NXT™
Preaction Valve



**UNITED Fire Systems
PREACTION-PAC
Shown with Doors Open**

UNITED FIRE SYSTEMS

Division of United Fire Protection Corporation
1 MARK ROAD

KENILWORTH, NJ 07033 USA

PHONE: 908-688-0300 FAX: 908-688-0218

www.unitedfiresystems.net

This literature is provided for informational purposes only. United Fire Protection Corporation assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to perform as intended.

Technical Service Bulletin

FireLock NXT™ Deluge and Preaction Actuated Valves Series 769 (All Sizes)



IF YOU OWN OR SERVICE A SERIES 769 FIRELOCK NXT™ DELUGE OR PREACTION ACTUATED VALVE, PLEASE READ AND FOLLOW THIS BULLETIN.

WHAT IS THE ISSUE?

If your sprinkler system contains a Victaulic Series 769 FireLock NXT Deluge or Preaction Actuated Valve, and the system is installed in an area where the water supply conditions are such that calcium or other mineral deposits could develop, you need to inspect the current condition of the Series 776 Low-Pressure Actuator, Series 767 Electric/Pneumatic Actuator, or Series 798 Pneumatic/Pneumatic Actuator for restriction of the air feed and auto vent orifices. The minerals present in the water may accumulate and cause a delay or an inoperable condition, preventing proper function of the sprinkler system.

WHAT SHOULD YOU DO?

In order to confirm proper function of the Series 776 Low-Pressure Actuator, Series 767 Electric/Pneumatic Actuator, or Series 798 Pneumatic/Pneumatic Actuator, Victaulic requests building owners to contact their fire protection contractor and schedule the completion of routine testing and inspection schedules provided by the National Fire Protection Association (NFPA). At that time, the manufacturing date of the valve can be confirmed. In standard NFPA 25 (Inspection Testing and Maintenance of Water-Based Fire Protection Systems), Chapter 13.4.4.2 defines the minimum inspection and testing requirements, including:

- A partial operational trip test to be performed annually
- A full operational trip test to be performed every 3 years
- A full internal inspection to be performed every 5 years

NFPA 25 states that these inspections and tests should be performed more frequently in the presence of contaminated, corrosive, and/or scaling water supplies or corrosive atmospheres. Additionally, the installation, maintenance, and testing manual, shipped with each valve, provides procedures for performing these tests and inspections.

To aid your fire protection contractor in determining if the valve(s) installed in your system are affected by this bulletin, please refer to the factory-installed identification tag attached to the valve body (see sample identification tag photo to the right).

Valves **manufactured prior to June 2010** may be equipped with a Series 776 Low-Pressure Actuator that is more susceptible to restriction.

Valves **manufactured prior to December 2010** may be equipped with a Series 767 Electric/Pneumatic Actuator or Series 798 Pneumatic/Pneumatic Actuator that is more susceptible to restriction.

If your contractor determines that remediation is necessary, they will call 1-855-861-1227 or e-mail Victaulic at engineering@victaulic.com for the necessary instructions and hardware in order to return your system to proper operation.



WHO IS AFFECTED BY THIS TECHNICAL SERVICE BULLETIN?

This technical service bulletin affects anyone responsible for the ongoing maintenance of a fire sprinkler system that uses the Series 769 FireLock NXT Deluge or Preaction Actuated Valve in combination with the Series 776 Low-Pressure Actuator **manufactured prior to June 2010** or a fire sprinkler system that uses the Series 769 FireLock NXT Preaction Valve in combination with the Series 767 Electric/Pneumatic Actuator or Series 798 Pneumatic/Pneumatic Actuator **manufactured prior to December 2010**.

If there is any uncertainty about whether this bulletin applies to your system, please contact a qualified local fire protection contractor who can assist in making this determination.

If your sprinkler system contains a different manufacturer's actuated valve, consult the manufacturer for their recommended inspection and maintenance procedures.