

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7080-2143:0100

**CATEGORY:** 7080 -- EXTINGUISHING SYSTEMS

**LISTEE:** UNITED FIRE SYSTEMS1 MARK ROAD, KENILWORTH, NJ 07033  
Contact: Stan Slonski (908) 688-0300 Ext: 238 Fax (908) 481-1131  
Email: sslonski@ufpco.com

**DESIGN:** Model PREACTION-PAC is a one zone pre-action fire suppression system consisting of a fully assembled: FM Approved Victaulic Series 769 FireLock NXT Preaction valve, trim, NRTL certified General Air compressor, and an FM Approved control panel board assembly model number NFS2-640 [Notifier], RP-2001 [Notifier], 4410-RC [Potter], FENWALNET-6000 [Fenwal], or no panel for retrofit to an existing FM Approved control panel. Contained within the system enclosure are all system components and accessories, requiring only the connection to the water supply inlet, water outlet (to system), main drain, the alarm and detection connections, and the electrical power supply. Refer to listee's printed data sheet for additional detailed product description and operational considerations

**RATING:** 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and FM label.

**APPROVAL:** Listed as a one zone pre-action fire suppression system. Refer to listee's Installation Instruction Manual for details.

11-15-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
Fire Engineering Division

**UFS-109 - 06 Jan 2020**  
Page 1 of 1