

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 5525-2143:0500 Page 1 of 1

**CATEGORY:** 5525 -- SPRINKLER SYSTEM ATTACHMENTS

**LISTEE:** UNITED FIRE SYSTEMS1 MARK ROAD, KENILWORTH, NJ 07033  
Contact: Stan Slonski (908) 688-0300 Ext: 238 Fax (908) 481-1131  
Email: sslonski@ufpco.com

**DESIGN:** Model AR-1 air release valve assembly in size 1/2 inch NPS. Refer to listee's printed data sheet for additional detailed product description and operational considerations

**RATING:** 175 psi max. working pressure

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rated working pressure and FM label.

**APPROVAL:** Listed as a air release valve for wet sprinkler systems. Refer to listee's Installation Instruction Manual for details.

12-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division

**UFS-706 - 07 Jan 2020**  
Page 1 of 1