



Certificate of Compliance

This certificate is issued for the following:

Nitrogen Generators

<i>Product Designation</i>	<i>Outlet Pipe Connection Size, NPS</i>	<i>Sprinkler System Capacity Gallon (liter)</i>	<i>Bypass Capacity Gallon (liter)</i>
NITROGEN-PAC SC-1S	1/2	800 (3 028)	300 (1 135)
NITROGEN-PAC SC-1M	1/2	1200 (4 540)	300 (1 135)
NITROGEN-PAC SC-2M	1/2	1600 (6 055)	475 (1 800)
NITROGEN-PAC SC-2L	1/2	4000 (15 140)	475 (1 800)

Prepared for:

UNITED Fire Systems
1 Mark Rd
Kenilworth, NJ 07033
United States

Manufactured at:

UNITED Fire Systems
1 Mark Rd
Kenilworth, NJ 07033
United States

FM Approvals Class: 1035 (December 2014)

Approval Identification: 3063735

Approval Granted: May 23, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group