

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7080-2143:0100

Page 1 of 1

CATEGORY: 7080 -- EXTINGUISHING SYSTEMS

LISTEE: UNITED FIRE SYSTEMS1 MARK ROAD, KENILWORTH, NJ 07033
Contact: Stan Slonski (908) 688-0300 Ext: 238 Fax (908) 481-1131
Email: sslonski@ufpco.com

DESIGN: Model PREACTION-PAC is a one zone pre-action fire suppression system consisting of a fully assembled: FM Approved Victaulic Series 769 FireLock NXT Preaction valve, trim, NRTL certified General Air compressor, and an FM Approved control panel board assembly model number NFS2-640 [Notifier], RP-2001 [Notifier], 4410-RC [Potter], FENWALNET-6000 [Fenwal], or no panel for retrofit to an existing FM Approved control panel. Contained within the system enclosure are all system components and accessories, requiring only the connection to the water supply inlet, water outlet (to system), main drain, the alarm and detection connections, and the electrical power supply. Refer to listee's printed data sheet for additional detailed product description and operational considerations

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and FM label.

APPROVAL: Listed as a one zone pre-action fire suppression system. Refer to listee's Installation Instruction Manual for details.

11-15-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division

UFS-109 - 10 Aug 2020
Page 1 of 1