

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5525-2143:0500 Page 1 of 1

CATEGORY: 5525 -- SPRINKLER SYSTEM ATTACHMENTS

LISTEE: UNITED FIRE SYSTEMS1 MARK ROAD, KENILWORTH, NJ 07033
Contact: Stan Slonski (908) 688-0300 Ext: 238 Fax (908) 481-1131
Email: sslonski@ufpco.com

DESIGN: Model AR-1 air release valve assembly in size 1/2 inch NPS. Refer to listee's printed data sheet for additional detailed product description and operational considerations

RATING: 175 psi max. working pressure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rated working pressure and FM label.

APPROVAL: Listed as a air release valve for wet sprinkler systems. Refer to listee's Installation Instruction Manual for details.

12-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division

UFS-706 - 10 Aug 2020
Page 1 of 1