



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

PREACTION-PAC pre-action fire suppression system

*Approval Guide* Listing: Category:

Electrical Signaling; Local Protective Signaling  
Automatic Sprinkler Systems; Preaction and Deluge Sprinkler Systems  
Automatic Sprinkler Systems; Refrigerated Area Sprinkler System

Listing appears on following pages.

United Fire Protection Corp  
1 Mark Road  
Kenilworth, NJ 07033 USA

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>		<i>Approval Standards</i>		<i>Other Standards</i>	
<i>Class Number</i>	<i>Date</i>	<i>Class Number</i>	<i>Date</i>	<i>Organization, Designation</i>	<i>Date</i>
3010	December 2010	1013	September 2009	ANSI/ NFPA 72	2002
1011	September 2009	1032	August 1970		
1012	September 2009	ANSI/NFPA 13	2007		

Original Approval Project Identification: 3037039

Approval Granted: July 19, 2011

Related Reports & Subsequent Revisions: 3037039rev130328\_33140-283, 3037039\_RR200921-283, 3037039\_RR201087-283, 3037039\_RR207692-283, 3037039\_RR208072-287, RR219231, RR226912.

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

A handwritten signature in dark ink, appearing to read "J.E. Marquedant".

J. E. Marquedant  
Manager of Electrical Systemtitle  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

26 May 2021

\_\_\_\_\_  
Date



Member of the FM Global Group

**UFS-106 Rev 3.00 - Jun 2021**