



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	5525-2143:0500
CATEGORY:	5525 - SPRINKLER SYSTEM ATTACHMENTS
LISTEE:	UNITED FIRE SYSTEMS 1 MARK ROAD, KENILWORTH, NJ, 07033 Contact: Kleber,Jonathan (908) 688-0300 (908) 481-1131 Email: jkleber@ufpco.com
DESIGN:	Model AR-1 air release valve assembly in size 1/2 inch NPS. Refer to listee's printed data sheet for additional detailed product description and operational considerations
RATING:	175 psi max. working pressure
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rated working pressure and FM label.
APPROVAL:	Listed as a air release valve for wet sprinkler systems. Refer to listee's Installation Instruction Manual for details.
NOTES:	

12-04-18 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/26/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division

**UFS-706 - 26 Jun 2025
Page 1 of 1**